


G:\LANL Engineering Standards\Eng. Manual [LEM]\2. Approved\ST-D30GEN-3M101.dwg, 09/18/03 @ 13:50 093598

H
G
F
E
D
C
B
A





MULTIPLE COIL PIPING DETAIL

SCALE: NONE

NOTES FOR DESIGNER:

1. SEE SHEET 11 FOR DESIGN NOTES.

DRAWING DEVELOPED FOR ML-3/
ML-4 PROJECTS. FOR ML-1/
ML-2, ADDITIONAL REQUIREMENTS
AND QA REVIEWS ARE REQUIRED.
(REMOVE THIS NOTE WHEN IN-
SERTED INTO A DRAWING PACK-
AGE).

1	6-14-03	U	REVISED TO COMPLY WITH DRAFTING MANUAL MOVED COIL UNIONS. DWG NO. WAS ST6121.	RP	AB	JM	GG	TO
NO	DATE	CLASS REV	DESCRIPTION	DWN	DSGN	CHKD	SUB	APP
 FACILITY & WASTE OPERATIONS DESIGN ENGINEERING CONSTRUCTION SERVICES								
ENGINEERING STANDARDS MANUAL				DRAWN R. PEARSON				
CHILLED/HOT WATER COIL PIPING DETAIL STACKED COILS				DESIGN A. BRIDGE				
				CHECKED G. GREWAL				
				DATE 6-28-99				
BLDG X				TA-X				
SUBMITTED				APPROVED FOR RELEASE				
DISCIPLINE POC: GURINDER GREWAL				STANDARDS MANAGER: TOBIN ORUCH				
 P.O. Box 1663 Los Alamos, New Mexico 87545				SHEET 10 OF 11				
CLASSIFICATION U				REVIEWER LARRY BAYS				DATE
PROJECT ID				DRAWING NO				REV 1
CHAPTER 6				ST-D30GEN-2				